

CERTIFICATE OF COMPLIANCE

Certificate Number 20150203-R21930
Report Reference R21930-20141129
Issue Date 2015-FEBRUARY-03

Issued to: BETA INDUSTRIAL L L C
ALQOUZ
P.O.BOX 50708
DUBAI UNITED ARAB EMIRATES

This is to certify that representative samples of DAMPERS FOR FIRE BARRIER AND SMOKE APPLICATIONS

Smoke Dampers Models:

Leakage Class II, Model BMSD & BMSD/R

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 555S, Fire Dampers

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

